

CITY OF KODIAK
Channel Transient Float Replacement
Project No. 17-07/8525

ADDENDUM NO. 1

DATE: October 11, 2016

BIDS DUE: **Thursday, October 27th, 2016 no later than 2:00:00 p.m. local time**

PAGES: Addendum, 1 page

Acknowledge receipt of this Addendum on the Proposal Form. Failure to do so may subject Proposer to disqualification. The following additions, corrections and/or changes are hereby made to the Contract Documents.

REQUEST FOR PROPOSALS, PROJECT APPROACH

Item 1 - ADD the following language immediately before Section 2.7.4 (A), Project Approach:

“A single Proposer may provide an unlimited number of baseline options (Project Approaches), on the condition that each option is accompanied by a firm price and in compliance with the RFP. The City will score each of the Proposer’s Project Approach options; only the option receiving the highest Technical score will go on to be included in a Total Score.”

APPENDIX F, FACILITY MINIMUM PERFORMANCE CRITERIA

Item 2 - ADD the following language to Section 6.2.2, Live Loads, Gangway Access:

“Design Vehicle: John Deere, Model X584 with snow thrower attachment”

Item 3 - DELETE the first bullet in Section 17.6, in its entirety and REPLACE with the following:

“All light fixtures shall be LED with a minimum IP 65 rating”

Item 4 - DELETE both bullets in Section 17.7, in their entirety and REPLACE with the following:

- “Main disconnect and MDP enclosures to be 304 Stainless Steel”
- CT cabinet to be 304 stainless steel, 316 stainless steel, or aluminum”

END OF ADDENDUM NO. 1