

CITY OF KODIAK
Channel Transient Float Replacement
Project No. 17-07/8525

ADDENDUM NO. 3

DATE: October 21, 2016

BIDS DUE: **Thursday, October 27th, 2016 no later than 2:00:00 p.m. local time**

PAGES: Addendum, 1 page

Acknowledge receipt of this Addendum on the Proposal Form. Failure to do so may subject Proposer to disqualification. The following additions, corrections and/or changes are hereby made to the Contract Documents:

APPENDIX F, FACILITY MINIMUM PERFORMANCE CRITERIA

Item 1 - DELETE the first sentence in Appendix F, Section 17.3 – Electrical Service, beginning with “Incoming service...” and REPLACE with the following:

“Incoming electrical service (by Others): maximum fault current on the Primary or High side of the transformer to be 4,000 amps with a 75 kVA transformer, 12,470Y/7,200 volts primary, 208Y/120 volts secondary. Transformer impedance will be 3.5%. System is intended to serve the following:”

Item 2 - DELETE Section 6.2.2 – Gangway Access Structure in Appendix F, in its entirety and REPLACE with the following:

“6.2.2 – Gangway Access Structure

Structural Live Load = 85 psf with a maximum deflection of L/360”

END OF ADDENDUM NO. 3