

CITY OF KODIAK
Channel Transient Float Replacement
Project No. 17-07/8525

QUESTIONS & ANSWERS NO.3

DATE: October 21, 2016

BIDS DUE: **THURSDAY, October 27th, 2016 no later than 2:00:00 p.m. local time**

APPENDIX F, FACILITY MINIMUM PERFORMANCE CRITERIA

26. Question: What is the available fault current that will be on the secondary side of the KEA transformer adjacent to the abutment so we can determine the correct AIC (amps interrupting rating) for the electrical equipment, as it has a significant effect on cost?

Response: Please reference Addendum No. 3.

27. Question: Project specification 6.0 General Loading Criteria Par. 6.2.2 which calls for a gangway that has a structural live load capacity of 100 psf – requesting that the uniform live load capacity of the gangway for this project be revised to 85 psf at a maximum deflection of L/360.

Response: Please reference Addendum No. 3

END OF QUESTIONS & ANSWERS NO.3